

# ABS PIPE 2.5M

(ABS008/27 – 2.5m)



**BISSON**  
THE PIPE FITTINGS EXPERTS

2.5 Meter ABS 27mm aspirating smoke detection pipes EN54 - 20 Approved. Pipe is designed for aspirating re detection only.

## Installation Instructions:

Do not bend the pipe. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Pipe clips are required every 800mm Only install with approved fittings. Do not use solvents to clean,

only soapy water. Only use approved pipe plastic cutters to cut the pipe. Ensure that pipe cutters are sharp. When ambient temperatures outside are 15°C to 25°C use pipe expansion joints. working temperatures between -40°C to +70°C.

PART NO.:	TEXT COLOUR:	TEST BY BSI TO:	TEXT DESCRIPTION
ABS008/27 – 2.5m	Black	EN54-20:2006 Clause 5.7	FIRE ALARM AIR SAMPLING PIPE
FITTINGS COLOUR:	DIAMETER TOLERANCE:	TEST REPORT	- DO NOT CUT OR PAINT
Red	+ / - 0.15mm'	3159127 - 02/03/2020	

### Bracket Spacing Intervals

Plastic pipe lines require regular support, and the spacing of clips or brackets depends on the pipe used, temperature and density of the liquid carried.

#### 25mm pipe size bracket spacing in meters

20°C	30°C	40°C	50°C	60°C	70°C
1.00	0.95	0.85	0.75	0.70	0.60

