ABS PIPE 2.5M (ABSG008/25 - 2.5m)



2.5 Meter ABS 25mm aspirating smoke detection pipes EN54 - 20 Approved. Pipe is designed for aspirating re detection only.

## Installation Instructions:

Do not bend the pipe. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Pipe clips are required every 800mm Only install with approved ttings. Do not use solvents to clean,

only soapy water. Only use approved pipe plastic cutters to cut the pipe. Ensure that pipe cutters are sharp. When ambient temperatures outside are 15°C to 25°C use pipe expansion joints. working temperatures between -40°C to +70°C.

PART NO .: **TEXT COLOUR:** TEST BY BSI TO: EN54-**TEXT DESCRIPTION:** ABSG008/25 - 2.5m Black 20:2006 Clause 5.7 FIRE ALARM AIR SAMPLING PIPE FITTINGS COLOUR: DIAMETER TOLERANCE: TEST REPORT - DO NOT CUT Grey + / - 0.15mm' 3159127 - 02/03/2020 **OR PAINT Bracket Spacing Intervals** 

Plastic pipe lines require regular support, and the spacing of clips or brackets depends on the pipe used, temperature and density of the liquid carried.

## 25mm pipe size bracket spacing in meters

20°C | 30°C | 40°C | 50°C | 60°C | 70°C 1.00 | 0.95 | 0.85 | 0.75 | 0.70 | 0.60

