



3 Meter PVC 25mm aspirating smoke detection pipes EN54 - 20 Approved. Pipe is designed for aspirating re detection only.

## Installation Instructions:

Do not bend the pipe. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Pipe clips are required every 800mm Only install with approved fittings. Do not use solvents to clean, only soapy water. Only use approved pipe plastic cutters to cut the pipe. Ensure that pipe cutters are sharp. When ambient temperatures outside are 15°C to 25°C use pipe expansion joints. working temperatures between -20°C to +50°C.

PART NO .: R-PVC008/25 - 3m TEXT COLOUR: Black

FITTINGS COLOUR: Red

**DIAMETER TOLERANCE:** + / - 0.15mm'

TEST BY BSI TO: EN54-20:2006 Clause 5.7

TEST REPORT 3159127 - 02/03/2020

## **TEXT DESCRIPTION**

FIRE ALARM AIR SAMPLING PIPE - DO NOT CUT OR PAINT



